

हरियाणा सरकार

Date: 02/4/2024

Sub:-

6

Approval of Fire Fighting Scheme from the fire safety point of view of the Group-B Educational Building mass of M/S PM Shri Govt. Sr. Building mens, 10699 Sq. Mtrs, Situated at Village Kunjpura, Distt, Karnal of M/S PM Shri/Govt, Sr. Sec. School Sec. School.

M/S PM Shri Govt, Sr. Sec, School submitted the subject cited case for Approval of Fire Fighting Scheme from fire safety point of view of the Group-B Educational Building meas. 10699 Sq. Mtrs. Situated at Village Kunjpura, Distt. Karnal through transaction 1D 110602423000091 Dated 18/03/2024. The office has examined the Fire Fighting Scheme in the drawing of above said building found that the building is an Educational Building Group-B. Fire tighting scheme shown in the Building Plans are found as per provision of Part-IV of National Building Code of India. 1983 revised from time to time and Haryana Fire & Emergency Services Act, 2022. The fire system designed Educational Building as per Part- IV of NBC 2016, is as under:-

Building Detail :-Name of Building :- PM Shri Govt. Sr. Sec. School.

1. Address of building :- Village Kunjpura, Distt. Karnal.

:- 10699 Sq. Mtrs.

Plot Area.

:- Group-B Educational Building

Type of Occupancy

:- 30 Mtrs.

5. Permissible Height	;- 30 Mis.		Remarks	
- Dotail-	:- Nil	Basement Area	Remark	\dashv
	Basement Level	- 111	,	╛
Tower No. / Name		Nil		
Nil	Nil		1	7
IVII .			Stair Case	_

Tower/Block Detail: Tower No. / Floor Are Name (Ground Coverage	a 140. 01 1 1001	Overall Height	Occupied Height	Min As per NBC	Stair Case As per Travel Distance	Provide
PM Shri Govt. Sr. Sec. School	trs. Ground Floor	4 M	4 M			

Fire Fighting System Detail-

Fire Fighting System Detail-		Required	Proposed provisions		
Sr. No.	Norms as per NBC, 2016	Required	Proposed		
1.	Fire Extinguishers	Required	Proposed		
2.	Hose Reel	N/R (Not Required)	N/A (Not Applicable)		
3.	Dry Riser	N/R	N/A		
4.	Wet Riser	N/R	N/A		
5.	Down Comer		N/A		
6.	Yard Hydrant	N/R	N/A		
7.	Automatic Sprinkler system	N/R			
8.	M.C.P.	N/R	N/A		
9.	Automatic Detection & Alarm System	N/R	N/A		
10.	U.G. Water Tank	N/R	N/A		
11.	Terrace Tank	Required 10+10+10+10 KL	Proposed 10 KL Admin Block & 3 Classroom Block		
12.	Pump near UG, Tank	N/R	N/A		
13.	Terrace Pump	Required 450+450+450+450 LPM	Proposed 450 LPM Admi Block & 3 Classroom Block		
14.	Domestic Tank would be connected with overflow of Fire Tank.	Required	Proposed		
15	Smoke Exhaust System & Fresh Air System in Basement	N/R	Natural		
16	Means of Escape	Required	Proposed		
17	Pressurization of Lift well	N/R	N/A		
18	Pressurization of Staircase/Louvers	N/R	N/A		
19	Compartmentation	N/R	N/A		
20	Exit Signage	Required	Proposed		

From the above, it is certified that the fire fighting scheme is as per Part-IV of NBC 1983 revised from time to time. Therefore, it is recommended that Fire Fighting Scheme may be approved subject to following conditions:-

The proposed Fire Fighting Scheme is approved as submitted in the building plan subject to the approval of building plan by the competent authority.

> Government of Haryana "नेटी ननाःशे-नेटी गटाःशे"